

EDD_FileData_tmp

SampID	ClientID	ClientSampID	Location	DateCollect	AnalysisDa	AnalyMatrix	TestNo	Analyte	Result	
CalBlank					10/6/16	AG	E200.8	Lead	<1.0	
1609L18-0BCSD	GCAFES3		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	1.3	
1609L18-0BCSD	G1DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	1.3	
1609L18-0BCSD	GCAFES1		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	1.6	
1609L18-0BCSD	G2DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	1.7	
1609L18-0BCSD	GCAFES2		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	1.8	
1609L18-0BCSD	G8DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	2.1	
1609L18-0BCSD	GFACS		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	2.2	
1609L18-0BCSD	GKITS2		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	2.3	
1609L18-0BCSD	G1ADF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	2.3	
1609L18-0BCSD	GNURSES		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	2.3	
1609L18-0BCSD	GMENBS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	2.5	
1609L18-0BCSD	GPRINBS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	2.6	
1609L18-0BCSD	GGIRLS1S		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	2.7	
1609L18-0BCSD	GLADIESBS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	2.8	
1609L18-0BCSD	G8S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	2.9	
1609L18-0BCSD	G3DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	2.9	
1609L18-0BCSD	G9DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	3.0	
1609L18-0BCSD	G3S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	3.1	
1609L18-0BCSD	G4DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	3.3	
1609L18-0BCSD	GGIRL2S		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	3.4	
1609L18-0BCSD	GARTS2		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	3.4	
1609L18-0BCSD	G2S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	3.6	
1609L18-0BCSD	G1ABS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	3.8	
1609L18-0BCSD	G5S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	3.9	
1609L18-0BCSD	G4S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	4.0	
1609L18-0BCSD	GARTS3		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	4.0	
1609L18-0BCSD	G1AS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	4.4	
1609L18-0BCSD	G1S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	4.4	
1609L18-0BCSD	G9S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	4.6	
1609L18-0BCSD	GARTS1		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	4.7	
1609L18-0BCSD	G5DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	5.3	
1609L18-0BCSD	GNURSEBS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	5.3	
1609L18-0BCSD	GGIRLS3S1		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	5.5	
1609L18-0BCSD	G7DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	5.6	
1609L18-0BCSD	GFACRESTB		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	5.9	
1609L18-0BCSD	GHALLDF		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	6.0	
1609L18-0BCSD	GBOYS1S		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	6.2	
1609L18-0BCSD	GBOYS2S1		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	6.2	
1609L18-0BCSD	G7S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	6.3	
1609L18-0BCSD	GGIRLS3S2		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	6.6	
1609L18-0BCSD	G6S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	6.6	
1609L18-0BCSD	G3BS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	7.1	
1609L18-0BCSD	G48S		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	7.2	
1609L18-0BCSD	GBOYS3S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	7.3	
1609L18-0BCSD	GLIBS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	7.3	
1609L18-0BCSD	G6DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	7.7	
1609L18-0BCSD	G4BS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	7.9	
1609L18-0BCSD	G10S		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	8.0	
1609L18-0BCSD	GKITS1		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	8.3	
1609L18-0BCSD	GBOYS2S2		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	8.7	
1609L18-0BCSD	G2BS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	8.7	
1609L18-0BCSD	GLIBBS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	10	
1609L18-0BCSD	GKITS3		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	11	
1609L18-0BCSD	G1BS		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	12	
1609L18-0BCSD	G33DF		GLENMO	9/17/16	10/7/16	AG	Potable W:E200.8	Lead	14	
1609L18-0BCSD	GKITSBS		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	18	Kitchen Bathroom Sink
1609L18-0BCSD	G10DF		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	24	Room 10 (Brands) Water Fountain
1609L18-0BCSD	GKITS4		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	140	Kitchen Sink #4
1609L18-0BCSD	GFACSB		GLENMO	9/17/16	10/19/16	CM	Potable W:E200.8	Lead	<1.0	