

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	Units
HS E HALL (E200) DF1	10/9/2016 09:42	11/9/2016 15:02	10368231262	Lead	0.16	ug/L
HS E BOY (E200)BS2	10/9/2016 09:40	11/9/2016 15:05	10368231265	Lead	0.16	ug/L
HS D 223S2	10/9/2016 11:15	11/9/2016 16:52	10368231205	Lead	0.18	ug/L
HS E HALL (E200) DF2	10/9/2016 09:42	11/9/2016 15:03	10368231263	Lead	0.18	ug/L
HS E BOY (E200)BS3	10/9/2016 09:40	11/9/2016 15:07	10368231266	Lead	0.19	ug/L
HS E GIRLS (E200)BS3	10/9/2016 09:45	11/9/2016 14:55	10368231261	Lead	0.2	ug/L
HS E GIRL (E100) BS3	10/9/2016 07:20	11/14/2016 16:13	10368231303	Lead	0.2	ug/L
HS E GIRLS (E200)BS2	10/9/2016 09:45	11/9/2016 17:56	10368231260	Lead	0.21	ug/L
HS E GIRLS (E200)BS1	10/9/2016 09:45	11/9/2016 17:55	10368231259	Lead	0.22	ug/L
HS E BOY (E200)BS1	10/9/2016 09:40	11/9/2016 15:04	10368231264	Lead	0.23	ug/L
HS D GIRL (D214) BS3	10/9/2016 11:28	11/9/2016 17:12	10368231215	Lead	0.24	ug/L
HS D GIRL (D114) BS2	10/9/2016 11:40	11/14/2016 21:51	10368231183	Lead	0.25	ug/L
HS D GIRL (D214) BS2	10/9/2016 11:28	11/9/2016 17:06	10368231214	Lead	0.25	ug/L
HS D GIRL (D114) BS3	10/9/2016 11:40	11/14/2016 21:55	10368231184	Lead	0.27	ug/L
HS E BOY (E100) BS3	10/9/2016 07:20	11/14/2016 16:17	10368231306	Lead	0.27	ug/L
HS D MEN (D252) BS1	10/9/2016 11:25	11/9/2016 17:00	10368231210	Lead	0.28	ug/L
HS D GIRL (D214) BS1	10/9/2016 11:28	11/9/2016 17:05	10368231213	Lead	0.28	ug/L
HS B LOCKER DF	10/9/2016 06:31	11/12/2016 21:17	10368231016	Lead	0.29	ug/L
HS E BOY (E100) BS2	10/9/2016 07:20	11/14/2016 16:16	10368231305	Lead	0.31	ug/L
HS BUSINESS BREAKS	10/9/2016 08:33	11/14/2016 21:27	10368231088	Lead	0.33	ug/L
HS D WOMEN (D252) BS2	10/9/2016 11:20	11/9/2016 16:57	10368231207	Lead	0.33	ug/L
HS C SESS S	10/9/2016 10:09	11/15/2016 11:54	10368231115	Lead	0.35	ug/L
HS A WING DF	10/9/2016 07:53	11/12/2016 22:49	10368231060	Lead	0.36	ug/L
HS D 223S1	10/9/2016 11:15	11/9/2016 16:51	10368231204	Lead	0.38	ug/L
HS D BOY (D212) BS3	10/9/2016 11:30	11/9/2016 17:16	10368231218	Lead	0.39	ug/L
HS D BOY (D112) BS2	10/9/2016 11:40	11/14/2016 21:57	10368231186	Lead	0.4	ug/L
HS D BOY (D112) BS3	10/9/2016 11:40	11/12/2016 21:39	10368231024	Lead	0.43	ug/L
HS A LADIES BS3	10/9/2016 07:52	11/12/2016 22:48	10368231059	Lead	0.44	ug/L
HS D 227 DARKS	10/9/2016 11:00	11/9/2016 16:44	10368231201	Lead	0.44	ug/L
HS D MEN (D252) BS2	10/9/2016 11:25	11/9/2016 17:01	10368231211	Lead	0.45	ug/L
HS D BOY (D212) BS2	10/9/2016 11:30	11/9/2016 17:14	10368231217	Lead	0.48	ug/L
HS COFFEE CM	10/9/2016 06:30	11/11/2016 19:36	10368231322	Lead	0.48	ug/L
HS C WING DF	10/9/2016 10:03	11/15/2016 11:45	10368231110	Lead	0.49	ug/L
HS E GIRL (E100) BS1	10/9/2016 07:20	11/14/2016 16:10	10368231302	Lead	0.49	ug/L
HS A LADIES BS2	10/9/2016 07:49	11/12/2016 22:47	10368231058	Lead	0.51	ug/L
HS C WOMEN BS	10/9/2016 10:07	11/15/2016 11:53	10368231114	Lead	0.53	ug/L

HS E WOMEN (E102) BS	10/9/2016 07:43	11/14/2016 16:06	10368231301	Lead	0.53	ug/L
HS A BOYS BS2	10/9/2016 07:55	11/14/2016 17:34	10368231062	Lead	0.54	ug/L
HS D 127S2	10/9/2016 11:44	11/14/2016 19:07	10368231169	Lead	0.55	ug/L
HS D HALL (D212) DF	10/9/2016 11:30	11/9/2016 17:17	10368231219	Lead	0.55	ug/L
HS D WOMEN (D252) BS1	10/9/2016 11:20	11/9/2016 16:55	10368231206	Lead	0.57	ug/L
HS D BOY (D112) BS1	10/9/2016 11:40	11/14/2016 21:56	10368231185	Lead	0.62	ug/L
HS D 127S1	10/9/2016 11:44	11/14/2016 19:06	10368231168	Lead	0.63	ug/L
HS D WOMEN (D153) BS2	10/9/2016 11:56	11/14/2016 19:17	10368231177	Lead	0.63	ug/L
HS CAFE DF1	10/9/2016 07:00	11/14/2016 16:19	10368231308	Lead	0.65	ug/L
HS D BOY (D212) BS1	10/9/2016 11:30	11/9/2016 17:13	10368231216	Lead	0.7	ug/L
HS CAFE DF2	10/9/2016 07:00	11/14/2016 16:20	10368231309	Lead	0.7	ug/L
HS B WING DF	10/9/2016 09:51	11/14/2016 21:39	10368231100	Lead	0.72	ug/L
HS D HALL (D252) DF2	10/9/2016 11:22	11/9/2016 16:59	10368231209	Lead	0.72	ug/L
HS D HALL (D214) DF	10/9/2016 11:26	11/9/2016 17:04	10368231212	Lead	0.74	ug/L
HS COFFEE S	10/9/2016 06:30	11/11/2016 19:38	10368231323	Lead	0.74	ug/L
HS D HALL (D252) DF1	10/9/2016 11:22	11/9/2016 16:58	10368231208	Lead	0.76	ug/L
HS G 166BS2	10/9/2016 07:29	11/12/2016 22:29	10368231049	Lead	0.78	ug/L
HS D 227S6	10/9/2016 11:00	11/14/2016 22:18	10368231200	Lead	0.79	ug/L
HS A BOYS BS3	10/9/2016 07:56	11/14/2016 17:42	10368231063	Lead	0.8	ug/L
HS D HALL (D150) DF1	10/9/2016 11:54	11/14/2016 19:22	10368231178	Lead	0.8	ug/L
HS A LADIES BS1	10/9/2016 07:48	11/12/2016 22:45	10368231057	Lead	0.81	ug/L
HS A BOYS BS1	10/9/2016 07:54	11/14/2016 17:35	10368231061	Lead	0.81	ug/L
HS C 100 BS	10/9/2016 09:59	11/15/2016 11:39	10368231105	Lead	0.84	ug/L
HS E MEN (E202) BS	10/9/2016 09:50	11/9/2016 17:48	10368231257	Lead	0.84	ug/L
HS B 121 COFFEE MAKER	10/9/2016 09:42	11/14/2016 21:38	10368231096	Lead	0.85	ug/L
HS GUIDANCES	10/9/2016 07:45	11/12/2016 22:44	10368231056	Lead	0.86	ug/L
HS E MEN (E102) BS	10/9/2016 07:43	11/10/2016 19:44	10368231300	Lead	0.87	ug/L
HS ELEV HALL DF	10/9/2016 07:05	11/12/2016 21:58	10368231035	Lead	0.88	ug/L
HS G 164BS2	10/9/2016 07:26	11/12/2016 22:32	10368231051	Lead	0.89	ug/L
HS F GIRL BS4	10/9/2016 06:20	11/14/2016 16:34	10368231320	Lead	0.92	ug/L
HS B TEAM BS3	10/9/2016 07:17	11/12/2016 22:21	10368231045	Lead	0.96	ug/L
HS A WOMEN BS	10/9/2016 07:59	11/14/2016 17:46	10368231066	Lead	0.96	ug/L
HS KITCHEN S6	10/9/2016 06:40	11/11/2016 19:54	10368231332	Lead	0.98	ug/L
HS C GIRLS BS2	10/9/2016 10:01	11/15/2016 11:42	10368231108	Lead	1.0	ug/L
HS ELEV GIRL BS2	10/9/2016 07:02	11/12/2016 21:57	10368231034	Lead	1.1	ug/L
HS ELEV BOY BS2	10/9/2016 07:07	11/12/2016 22:01	10368231037	Lead	1.1	ug/L
HS B TEAM BS4	10/9/2016 07:17	11/12/2016 22:25	10368231046	Lead	1.1	ug/L
HS G 166BS1	10/9/2016 07:28	11/12/2016 22:28	10368231048	Lead	1.1	ug/L

HS C MEN BS	10/9/2016 10:00	11/15/2016 11:40	10368231106	Lead	1.1	ug/L
HS C GIRLS BS1	10/9/2016 10:01	11/15/2016 11:41	10368231107	Lead	1.1	ug/L
HS F GIRL BS2	10/9/2016 06:20	11/14/2016 16:32	10368231318	Lead	1.1	ug/L
HS KITCHEN S1	10/9/2016 06:35	11/11/2016 19:31	10368231321	Lead	1.1	ug/L
HS F 101 S1	10/9/2016 06:55	11/11/2016 20:06	10368231339	Lead	1.1	ug/L
HS GYM LOBBY DF1	10/9/2016 06:37	11/12/2016 21:25	10368231019	Lead	1.2	ug/L
HS FITNESS CTR IM	10/9/2016 06:42	11/12/2016 21:37	10368231022	Lead	1.2	ug/L
HS FITNESS CTR DF	10/9/2016 06:43	11/12/2016 21:38	10368231023	Lead	1.2	ug/L
NS NURSE BS1	10/9/2016 07:30	11/12/2016 22:35	10368231052	Lead	1.2	ug/L
HS D 125S2	10/9/2016 11:47	11/14/2016 19:09	10368231171	Lead	1.2	ug/L
HS D HALL (D114) DF1	10/9/2016 11:40	11/14/2016 21:50	10368231182	Lead	1.2	ug/L
HS E 100 PREP S	10/9/2016 07:25	11/9/2016 15:17	10368231272	Lead	1.2	ug/L
HS F HALL (F102) DF	10/9/2016 06:13	11/11/2016 20:04	10368231338	Lead	1.2	ug/L
HS GYM LOBBY DF2	10/9/2016 06:38	11/12/2016 21:26	10368231020	Lead	1.3	ug/L
HS C GYM HALL DF1	10/9/2016 06:59	11/12/2016 21:49	10368231031	Lead	1.3	ug/L
HS GYM B HALL DF	10/9/2016 07:09	11/12/2016 22:02	10368231038	Lead	1.3	ug/L
HS A 104S	10/9/2016 07:58	11/14/2016 17:45	10368231065	Lead	1.3	ug/L
HS C GIRLS BS3	10/9/2016 10:01	11/15/2016 11:43	10368231109	Lead	1.3	ug/L
HS D 128S	10/9/2016 11:59	11/14/2016 22:11	10368231194	Lead	1.3	ug/L
HS D 225 S1	10/9/2016 11:05	11/9/2016 16:48	10368231202	Lead	1.3	ug/L
HS B TEAM DF3	10/9/2016 07:16	11/12/2016 22:19	10368231043	Lead	1.4	ug/L
HS G 164BS1	10/9/2016 07:25	11/12/2016 22:31	10368231050	Lead	1.4	ug/L
HS A 103S2	10/9/2016 08:17	11/14/2016 21:14	10368231081	Lead	1.4	ug/L
HS C BOYS BS2	10/9/2016 10:04	11/15/2016 11:49	10368231112	Lead	1.4	ug/L
HS COFFEE IM	10/9/2016 06:30	11/11/2016 19:39	10368231324	Lead	1.4	ug/L
HS G LOCKER DF1	10/9/2016 06:16	11/12/2016 21:04	10368231008	Lead	1.5	ug/L
HS C GYM HALL DF2	10/9/2016 07:00	11/12/2016 21:54	10368231032	Lead	1.5	ug/L
HS GYM ADF	10/9/2016 06:12	11/12/2016 20:58	10368231005	Lead	1.6	ug/L
HS B TEAM DF2	10/9/2016 07:15	11/12/2016 22:17	10368231042	Lead	1.6	ug/L
HS B 106S1	10/9/2016 08:34	11/14/2016 21:28	10368231089	Lead	1.6	ug/L
HS B 121 S	10/9/2016 08:46	11/14/2016 21:33	10368231095	Lead	1.6	ug/L
HS D 125S1	10/9/2016 11:46	11/14/2016 19:08	10368231170	Lead	1.6	ug/L
HS FACULTY ROOMS	10/9/2016 07:05	11/14/2016 16:21	10368231310	Lead	1.6	ug/L
HS KITCHEN S4	10/9/2016 06:38	11/11/2016 19:47	10368231328	Lead	1.6	ug/L
HS E 106S2	10/9/2016 07:57	11/10/2016 19:19	10368231285	Lead	1.7	ug/L
HS E 106S4	10/9/2016 07:57	11/10/2016 19:24	10368231287	Lead	1.7	ug/L
HS B TEAM DF1	10/9/2016 07:13	11/12/2016 22:05	10368231040	Lead	1.8	ug/L
HS MAIN OFFICES	10/9/2016 07:42	11/12/2016 22:43	10368231055	Lead	1.8	ug/L

HS C BOYS BS1	10/9/2016 10:04	11/15/2016 11:48	10368231111	Lead	1.8	ug/L
HS D WOMEN (D153) BS1	10/9/2016 11:56	11/14/2016 19:15	10368231176	Lead	1.8	ug/L
HS D HALL (D111) DF	10/9/2016 11:50	11/14/2016 21:58	10368231187	Lead	1.8	ug/L
HS D 227S3	10/9/2016 11:00	11/14/2016 22:15	10368231197	Lead	1.8	ug/L
HS D 224S2	10/9/2016 11:10	11/10/2016 13:47	10368231224	Lead	1.8	ug/L
HS F GIRL BS3	10/9/2016 06:20	11/14/2016 16:33	10368231319	Lead	1.8	ug/L
HS A 105S1	10/9/2016 08:15	11/14/2016 18:06	10368231079	Lead	1.9	ug/L
HS C BOYS BS3	10/9/2016 10:05	11/15/2016 11:52	10368231113	Lead	1.9	ug/L
HS D 124S5	10/9/2016 11:55	11/14/2016 22:05	10368231192	Lead	1.9	ug/L
HS E 102S3	10/9/2016 07:35	11/9/2016 15:21	10368231275	Lead	1.9	ug/L
HS KITCHEN KETTLE 1	10/9/2016 06:40	11/11/2016 19:50	10368231330	Lead	1.9	ug/L
HSG100DF	10/9/2016 06:07	11/12/2016 20:48	10368231001	Lead	2.0	ug/L
HS G TEAM BS2	10/9/2016 06:54	11/12/2016 21:45	10368231028	Lead	2.0	ug/L
HS B TEAM BS2	10/9/2016 07:16	11/12/2016 22:20	10368231044	Lead	2.0	ug/L
HS C 107S4	10/9/2016 10:15	11/15/2016 11:59	10368231119	Lead	2.0	ug/L
HS C 103S12	10/9/2016 11:24	11/14/2016 21:30	10368231152	Lead	2.0	ug/L
HS D 125S4	10/9/2016 11:51	11/14/2016 19:13	10368231173	Lead	2.0	ug/L
HS D MEN (D150) BS2	10/9/2016 11:52	11/14/2016 21:45	10368231181	Lead	2.0	ug/L
HS E 106S3	10/9/2016 07:57	11/10/2016 19:23	10368231286	Lead	2.0	ug/L
HS KITCHEN KETTLE 2	10/9/2016 06:40	11/11/2016 19:51	10368231331	Lead	2.0	ug/L
HS OUTSIDE GYM B FAUCET	10/9/2016 06:45	11/7/2016 20:50	10368231344	Lead	2.0	ug/L
HS G LOCKER S1	10/9/2016 06:17	11/12/2016 21:06	10368231009	Lead	2.1	ug/L
HS C 103 S4	10/9/2016 11:19	11/14/2016 21:17	10368231144	Lead	2.1	ug/L
HS C 103S8	10/9/2016 11:21	11/14/2016 21:21	10368231148	Lead	2.1	ug/L
HS ELEV BOY BS1	10/9/2016 07:06	11/12/2016 22:00	10368231036	Lead	2.2	ug/L
HS B MEN BS3	10/9/2016 09:54	11/15/2016 11:37	10368231103	Lead	2.2	ug/L
HS D 227S2	10/9/2016 11:00	11/14/2016 22:14	10368231196	Lead	2.2	ug/L
HS E BOY (E100) BS1	10/9/2016 07:20	11/14/2016 16:14	10368231304	Lead	2.2	ug/L
HS F BOY BS1	10/9/2016 06:27	11/14/2016 16:22	10368231311	Lead	2.2	ug/L
HS G TEAM BS3	10/9/2016 06:55	11/12/2016 21:46	10368231029	Lead	2.3	ug/L
HS A 103S1	10/9/2016 08:16	11/14/2016 18:11	10368231080	Lead	2.3	ug/L
HS C 103 S2	10/9/2016 11:18	11/14/2016 21:14	10368231142	Lead	2.3	ug/L
HS C 103S11	10/9/2016 11:24	11/14/2016 21:27	10368231151	Lead	2.3	ug/L
HS E 105S4	10/9/2016 08:10	11/10/2016 19:41	10368231298	Lead	2.3	ug/L
HS F BOY BS2	10/9/2016 06:27	11/14/2016 16:28	10368231312	Lead	2.3	ug/L
HS F GIRL BS1	10/9/2016 06:20	11/14/2016 16:31	10368231317	Lead	2.3	ug/L
HS ELEV GIRL BS1	10/9/2016 07:01	11/12/2016 21:56	10368231033	Lead	2.4	ug/L
HS A 101 S3	10/9/2016 08:27	11/14/2016 21:26	10368231087	Lead	2.4	ug/L

HS C 101 S2	10/9/2016 11:29	11/14/2016 21:35	10368231156	Lead	2.4	ug/L
HS E 102S1	10/9/2016 07:35	11/9/2016 15:19	10368231273	Lead	2.4	ug/L
HS E 104S1	10/9/2016 07:50	11/9/2016 15:25	10368231278	Lead	2.4	ug/L
HS C 103S7	10/9/2016 11:21	11/14/2016 21:20	10368231147	Lead	2.5	ug/L
HS E 202S4	10/9/2016 09:53	11/10/2016 14:07	10368231234	Lead	2.5	ug/L
HS A 110 S2	10/9/2016 08:23	11/14/2016 21:24	10368231085	Lead	2.6	ug/L
HS C 105 S3B	10/9/2016 10:50	11/14/2016 18:42	10368231136	Lead	2.6	ug/L
HS E 100 S2	10/9/2016 07:25	11/9/2016 15:09	10368231268	Lead	2.6	ug/L
HS KITCHEN S2	10/9/2016 06:37	11/11/2016 19:43	10368231325	Lead	2.6	ug/L
HS G LOCKER S3	10/9/2016 06:22	11/12/2016 21:13	10368231013	Lead	2.7	ug/L
HS C 105 S1B	10/9/2016 10:43	11/14/2016 18:33	10368231132	Lead	2.7	ug/L
HS E 200 PREP2	10/9/2016 09:53	11/10/2016 14:01	10368231230	Lead	2.7	ug/L
HS B MEN BS2	10/9/2016 09:53	11/15/2016 11:36	10368231102	Lead	2.8	ug/L
HS C 101 S1	10/9/2016 11:28	11/14/2016 21:33	10368231155	Lead	2.8	ug/L
HS C 101 S10	10/9/2016 11:36	11/14/2016 18:59	10368231164	Lead	2.8	ug/L
HS C 101 S11	10/9/2016 11:37	11/14/2016 19:00	10368231165	Lead	2.8	ug/L
HS D HALL (D150) DF2	10/9/2016 11:54	11/14/2016 19:23	10368231179	Lead	2.8	ug/L
HS D 225 S2	10/9/2016 11:05	11/9/2016 16:49	10368231203	Lead	2.8	ug/L
HS G TEAM BS1	10/9/2016 06:53	11/12/2016 21:43	10368231027	Lead	2.9	ug/L
HS A 106S2	10/9/2016 08:01	11/14/2016 17:48	10368231068	Lead	2.9	ug/L
HS C 103 S1	10/9/2016 11:17	11/14/2016 21:07	10368231141	Lead	2.9	ug/L
HS E WOMEN (E202) BS	10/9/2016 09:50	11/9/2016 17:49	10368231258	Lead	2.9	ug/L
HS G LOCKER S2	10/9/2016 06:19	11/12/2016 21:08	10368231011	Lead	3.0	ug/L
HS C 107S6	10/9/2016 10:17	11/14/2016 18:13	10368231121	Lead	3.0	ug/L
HS C 107S12	10/9/2016 10:24	11/14/2016 18:26	10368231127	Lead	3.0	ug/L
HS C 103 S6	10/9/2016 11:20	11/14/2016 21:19	10368231146	Lead	3.0	ug/L
HS D 224S1	10/9/2016 11:10	11/10/2016 13:45	10368231223	Lead	3.0	ug/L
HS C 103 S3	10/9/2016 11:19	11/14/2016 21:16	10368231143	Lead	3.1	ug/L
HS KITCHEN S5	10/9/2016 06:38	11/11/2016 19:48	10368231329	Lead	3.1	ug/L
HS C 107S10	10/9/2016 10:22	11/14/2016 18:23	10368231125	Lead	3.2	ug/L
HS D 227S1	10/9/2016 11:00	11/14/2016 22:12	10368231195	Lead	3.2	ug/L
HS E 104S4	10/9/2016 07:50	11/10/2016 19:11	10368231281	Lead	3.2	ug/L
HS C 107S1	10/9/2016 10:12	11/15/2016 11:55	10368231116	Lead	3.3	ug/L
HS C 101 S3	10/9/2016 11:30	11/14/2016 21:36	10368231157	Lead	3.3	ug/L
HS D 222S3	10/9/2016 11:17	11/10/2016 13:44	10368231222	Lead	3.3	ug/L
HS E 204 PREPS1	10/9/2016 10:20	11/9/2016 17:38	10368231250	Lead	3.3	ug/L
HS MAIN LOBBY DF	10/9/2016 06:10	11/12/2016 20:56	10368231004	Lead	3.4	ug/L
HS E 200 S4	10/9/2016 09:52	11/10/2016 13:58	10368231228	Lead	3.4	ug/L

HS E 204S8	10/9/2016 10:15	11/9/2016 17:28	10368231243	Lead	3.4	ug/L
HS B TEAM OFFICE BS	10/9/2016 07:14	11/12/2016 22:12	10368231041	Lead	3.5	ug/L
HS C 103S9	10/9/2016 11:23	11/14/2016 21:23	10368231149	Lead	3.5	ug/L
HS D 227S4	10/9/2016 11:00	11/14/2016 22:16	10368231198	Lead	3.5	ug/L
HS C 107S2	10/9/2016 10:14	11/15/2016 11:56	10368231117	Lead	3.6	ug/L
HS C 107S5	10/9/2016 10:16	11/15/2016 12:04	10368231120	Lead	3.6	ug/L
HS C 105 S2B	10/9/2016 10:49	11/14/2016 18:40	10368231134	Lead	3.6	ug/L
HS C 101 S6	10/9/2016 11:32	11/14/2016 21:44	10368231160	Lead	3.6	ug/L
HS E 200 S1	10/9/2016 09:52	11/10/2016 13:48	10368231225	Lead	3.6	ug/L
HS E 202S2	10/9/2016 09:53	11/10/2016 14:04	10368231232	Lead	3.6	ug/L
HS E 202S5	10/9/2016 09:53	11/10/2016 14:13	10368231235	Lead	3.6	ug/L
HS E 105S3	10/9/2016 08:10	11/10/2016 19:40	10368231297	Lead	3.6	ug/L
HS C 101 S5	10/9/2016 11:31	11/14/2016 21:43	10368231159	Lead	3.7	ug/L
HS D 126S	10/9/2016 11:58	11/14/2016 22:10	10368231193	Lead	3.7	ug/L
HS E 202S1	10/9/2016 09:53	11/10/2016 14:02	10368231231	Lead	3.7	ug/L
HS E 100 S4	10/9/2016 07:25	11/9/2016 15:12	10368231270	Lead	3.7	ug/L
HS C 101 S12	10/9/2016 11:37	11/14/2016 19:01	10368231166	Lead	3.8	ug/L
HS B LOCKER S2	10/9/2016 06:34	11/12/2016 21:23	10368231018	Lead	3.9	ug/L
HS A 109S1	10/9/2016 08:03	11/14/2016 17:51	10368231070	Lead	3.9	ug/L
HS C 101 S4	10/9/2016 11:30	11/14/2016 21:37	10368231158	Lead	3.9	ug/L
HS E 107S1	10/9/2016 08:05	11/10/2016 19:26	10368231289	Lead	3.9	ug/L
HS C 107S3	10/9/2016 10:14	11/15/2016 11:58	10368231118	Lead	4.0	ug/L
HS C 105 S5B	10/9/2016 10:58	11/14/2016 18:47	10368231140	Lead	4.0	ug/L
HS W OFFICIAL BS	10/9/2016 06:58	11/12/2016 21:48	10368231030	Lead	4.1	ug/L
HS E 200 S2	10/9/2016 09:52	11/10/2016 13:55	10368231226	Lead	4.1	ug/L
HS E 200 S3	10/9/2016 09:52	11/10/2016 13:57	10368231227	Lead	4.2	ug/L
HS E 104S5	10/9/2016 07:50	11/10/2016 19:16	10368231282	Lead	4.2	ug/L
HS B LOCKER S1	10/9/2016 06:32	11/12/2016 21:22	10368231017	Lead	4.3	ug/L
HS E 204S7	10/9/2016 10:15	11/9/2016 17:26	10368231242	Lead	4.3	ug/L
HS E 206S1	10/9/2016 10:30	11/9/2016 17:39	10368231251	Lead	4.3	ug/L
HS E 206S6	10/9/2016 10:30	11/9/2016 17:47	10368231256	Lead	4.3	ug/L
HS E 105S1	10/9/2016 08:10	11/10/2016 19:38	10368231295	Lead	4.3	ug/L
HS E 204S3	10/9/2016 10:15	11/10/2016 14:17	10368231238	Lead	4.4	ug/L
HS E 102S2	10/9/2016 07:35	11/9/2016 15:20	10368231274	Lead	4.4	ug/L
HS E 104S3	10/9/2016 07:50	11/9/2016 15:27	10368231280	Lead	4.4	ug/L
HS B LOCKER OFFICES	10/9/2016 06:30	11/12/2016 21:15	10368231015	Lead	4.5	ug/L
HS C 101 S9	10/9/2016 11:35	11/14/2016 18:57	10368231163	Lead	4.5	ug/L
HS F HALL (F119) DF	10/9/2016 06:05	11/7/2016 20:48	10368231342	Lead	4.5	ug/L

HS POOL OFFICES	10/9/2016 06:27	11/12/2016 21:14	10368231014	Lead	4.6	ug/L
HS D MEN (D150) BS1	10/9/2016 11:52	11/14/2016 19:25	10368231180	Lead	4.6	ug/L
HS E 100 S3	10/9/2016 07:25	11/9/2016 15:10	10368231269	Lead	4.6	ug/L
HS E 107S4	10/9/2016 08:05	11/10/2016 19:31	10368231292	Lead	4.6	ug/L
HS F HALL (STAGE) DF	10/9/2016 06:14	11/7/2016 20:47	10368231341	Lead	4.6	ug/L
HS A 107S1	10/9/2016 08:10	11/14/2016 18:01	10368231075	Lead	4.7	ug/L
HS D 222S1	10/9/2016 11:17	11/9/2016 17:18	10368231220	Lead	4.7	ug/L
HS D 222S2	10/9/2016 11:17	11/10/2016 13:39	10368231221	Lead	4.7	ug/L
HSWOMENBS1	10/9/2016 06:08	11/12/2016 20:54	10368231002	Lead	4.8	ug/L
HS FITNESS CTR BOYS BS	10/9/2016 06:40	11/12/2016 21:29	10368231021	Lead	4.8	ug/L
HS A 107S2	10/9/2016 08:11	11/14/2016 18:02	10368231076	Lead	4.8	ug/L
HS C 107S7	10/9/2016 10:18	11/14/2016 18:17	10368231122	Lead	4.8	ug/L
HS C 103 S5	10/9/2016 11:20	11/14/2016 21:18	10368231145	Lead	4.8	ug/L
HS C 101 S7	10/9/2016 11:33	11/14/2016 18:52	10368231161	Lead	4.8	ug/L
HS E 105S2	10/9/2016 08:10	11/10/2016 19:39	10368231296	Lead	4.8	ug/L
HS CAFE S	10/9/2016 07:00	11/14/2016 16:18	10368231307	Lead	4.8	ug/L
HSWOMENBS2	10/9/2016 06:09	11/12/2016 20:55	10368231003	Lead	4.9	ug/L
HS C 107S11	10/9/2016 10:23	11/14/2016 18:24	10368231126	Lead	4.9	ug/L
HS E 206S4	10/9/2016 10:30	11/9/2016 17:44	10368231254	Lead	4.9	ug/L
HS C 101 S8	10/9/2016 11:34	11/14/2016 18:56	10368231162	Lead	5.0	ug/L
HS B 108 S2	10/9/2016 08:42	11/14/2016 21:32	10368231094	Lead	5.1	ug/L
HS C 105 S3A	10/9/2016 10:49	11/14/2016 18:41	10368231135	Lead	5.1	ug/L
HS E 204S2	10/9/2016 10:15	11/10/2016 14:15	10368231237	Lead	5.1	ug/L
HS C 107S9	10/9/2016 10:21	11/14/2016 18:20	10368231124	Lead	5.2	ug/L
HS E 202S3	10/9/2016 09:53	11/10/2016 14:06	10368231233	Lead	5.2	ug/L
HS E 204S5	10/9/2016 10:15	11/10/2016 14:19	10368231240	Lead	5.2	ug/L
HS E 204S4	10/9/2016 10:15	11/10/2016 14:18	10368231239	Lead	5.3	ug/L
HS FITNESS CTR GIRL BS	10/9/2016 06:45	11/12/2016 21:41	10368231025	Lead	5.5	ug/L
HS C 107S8	10/9/2016 10:21	11/14/2016 18:19	10368231123	Lead	5.5	ug/L
HS E 200 S5	10/9/2016 09:52	11/10/2016 14:00	10368231229	Lead	5.5	ug/L
HS A 103S3	10/9/2016 08:20	11/14/2016 21:18	10368231082	Lead	5.6	ug/L
HS C 105 S2A	10/9/2016 10:48	11/14/2016 18:34	10368231133	Lead	5.8	ug/L
HS E 204S1	10/9/2016 10:15	11/10/2016 14:14	10368231236	Lead	5.9	ug/L
HS F RESTROOM (F119) BS	10/9/2016 06:07	11/7/2016 20:49	10368231343	Lead	5.9	ug/L
HS B MEN BS1	10/9/2016 09:52	11/15/2016 11:29	10368231101	Lead	6.0	ug/L
HS DISH S	10/9/2016 06:38	11/11/2016 19:44	10368231326	Lead	6.0	ug/L
HS C 105 S4B	10/9/2016 10:52	11/14/2016 18:44	10368231138	Lead	6.1	ug/L
HS D 125S6	10/9/2016 11:54	11/15/2016 11:15	10368231175	Lead	6.1	ug/L

HS D 124S2	10/9/2016 11:55	11/14/2016 22:01	10368231189	Lead	6.1	ug/L
HS D 124S1	10/9/2016 11:55	11/14/2016 21:59	10368231188	Lead	6.2	ug/L
HS E 204S10	10/9/2016 10:15	11/9/2016 17:30	10368231245	Lead	6.2	ug/L
HS E 104S2	10/9/2016 07:50	11/9/2016 15:26	10368231279	Lead	6.2	ug/L
HS C 105 S4A	10/9/2016 10:51	11/14/2016 18:43	10368231137	Lead	6.4	ug/L
HS E 204S6	10/9/2016 10:15	11/9/2016 17:19	10368231241	Lead	6.5	ug/L
HS D 227S5	10/9/2016 11:00	11/14/2016 22:17	10368231199	Lead	6.6	ug/L
HS G 5BS	10/9/2016 07:22	11/12/2016 22:26	10368231047	Lead	6.8	ug/L
HS E 100 S5	10/9/2016 07:25	11/9/2016 15:13	10368231271	Lead	7.1	ug/L
HS E 107S3	10/9/2016 08:05	11/10/2016 19:29	10368231291	Lead	7.1	ug/L
HS E 204S9	10/9/2016 10:15	11/9/2016 17:29	10368231244	Lead	7.2	ug/L
HS E 107S2	10/9/2016 08:05	11/10/2016 19:27	10368231290	Lead	7.2	ug/L
HS F 101 S2	10/9/2016 06:55	11/11/2016 20:07	10368231340	Lead	7.2	ug/L
HS A MEN BS	10/9/2016 07:57	11/14/2016 17:44	10368231064	Lead	7.3	ug/L
NS NURSE BS2	10/9/2016 07:37	11/12/2016 22:36	10368231053	Lead	7.4	ug/L
HS C 103 PREP S	10/9/2016 11:27	11/14/2016 21:32	10368231154	Lead	7.4	ug/L
HS E 102S4	10/9/2016 07:35	11/9/2016 15:22	10368231276	Lead	7.4	ug/L
HS E 206S3	10/9/2016 10:30	11/9/2016 17:43	10368231253	Lead	7.5	ug/L
HS D 125S5	10/9/2016 11:53	11/14/2016 19:14	10368231174	Lead	7.6	ug/L
HS G LOCKER OFFICE 2S	10/9/2016 06:21	11/12/2016 21:11	10368231012	Lead	7.8	ug/L
HS E 206S2	10/9/2016 10:30	11/9/2016 17:42	10368231252	Lead	7.8	ug/L
HS A 109S2	10/9/2016 08:04	11/14/2016 17:54	10368231071	Lead	8.1	ug/L
HS D 124S4	10/9/2016 11:55	11/14/2016 22:03	10368231191	Lead	8.2	ug/L
HS A 101 S2	10/9/2016 08:26	11/14/2016 21:25	10368231086	Lead	8.5	ug/L
HS KITCHEN S3	10/9/2016 06:38	11/11/2016 19:46	10368231327	Lead	8.6	ug/L
HS E 105S5	10/9/2016 08:10	11/10/2016 19:43	10368231299	Lead	8.8	ug/L
HS C 103S10	10/9/2016 11:23	11/14/2016 21:26	10368231150	Lead	8.9	ug/L
HS F 105S1	10/9/2016 06:12	11/11/2016 20:02	10368231336	Lead	9.1	ug/L
HS B TEAM BS1	10/9/2016 07:12	11/12/2016 22:04	10368231039	Lead	9.2	ug/L
HS D 124S3	10/9/2016 11:55	11/14/2016 22:02	10368231190	Lead	9.3	ug/L
HS E 204S12	10/9/2016 10:15	11/9/2016 17:32	10368231247	Lead	9.4	ug/L
HS E 104 PREP S	10/9/2016 07:50	11/10/2016 19:17	10368231283	Lead	9.5	ug/L
HS A 106S3	10/9/2016 08:02	11/14/2016 17:50	10368231069	Lead	10.1	ug/L
HS E 107S5	10/9/2016 08:05	11/10/2016 19:32	10368231293	Lead	10.3	ug/L
HS E 102S5	10/9/2016 07:35	11/9/2016 15:24	10368231277	Lead	10.7	ug/L
HS C 105 S5A	10/9/2016 10:58	11/14/2016 18:46	10368231139	Lead	11.0	ug/L
HS E 204S13	10/9/2016 10:15	11/9/2016 17:34	10368231248	Lead	11.6	ug/L
HS E 206S5	10/9/2016 10:30	11/9/2016 17:45	10368231255	Lead	11.6	ug/L



HS E 106S1	10/9/2016 07:57	11/10/2016 19:18	10368231284	Lead	11.8	ug/L	
HS C 105 S1A	10/9/2016 10:43	11/14/2016 18:30	10368231131	Lead	12.0	ug/L	
HS E 106S5	10/9/2016 07:57	11/10/2016 19:25	10368231288	Lead	12.1	ug/L	
HS C 101 S13	10/9/2016 11:40	11/14/2016 19:02	10368231167	Lead	12.4	ug/L	
HS A 103S4	10/9/2016 08:21	11/14/2016 21:19	10368231083	Lead	12.5	ug/L	
HS C 103S13	10/9/2016 11:26	11/14/2016 21:31	10368231153	Lead	12.8	ug/L	
HS E 100 S1	10/9/2016 07:25	11/9/2016 15:08	10368231267	Lead	13.5	ug/L	
HS F 107S2	10/9/2016 06:10	11/11/2016 20:00	10368231335	Lead	13.8	ug/L	
HS F 105S2	10/9/2016 06:12	11/11/2016 20:03	10368231337	Lead	14.3	ug/L	
HS E 204S11	10/9/2016 10:15	11/9/2016 17:31	10368231246	Lead	14.8	ug/L	
HS B 108 S1	10/9/2016 08:41	11/14/2016 21:30	10368231093	Lead	15.7	ug/L	HS Room B108 Sink 1
HS B 106S2	10/9/2016 08:35	11/14/2016 21:29	10368231090	Lead	16.5	ug/L	HS Room B106 Sink 2
HS A 109S3	10/9/2016 08:05	11/14/2016 17:57	10368231072	Lead	16.6	ug/L	HS Room A109 Sink 3
HS F WING DF1	10/9/2016 06:25	11/14/2016 16:29	10368231315	Lead	17.2	ug/L	HS Fwing Drinking Fountain 1
HS F WING DF2	10/9/2016 06:25	11/14/2016 16:30	10368231316	Lead	17.3	ug/L	HS Fwing Drinking Fountain 2
HS G LOCKER OFFICE 1S	10/9/2016 06:18	11/12/2016 21:07	10368231010	Lead	17.4	ug/L	HS Girls Locker Room Office Sink 1
HS A 107S4	10/9/2016 08:13	11/14/2016 18:05	10368231078	Lead	17.8	ug/L	HS Room A107 Sink 4
HS F 107S1	10/9/2016 06:10	11/11/2016 19:55	10368231334	Lead	18.2	ug/L	HS Room F107 Sink 1
HS E 204S14	10/9/2016 10:15	11/9/2016 17:35	10368231249	Lead	20.4	ug/L	HS Room E204 Sink Facuet 14
HS MEN BS1	10/9/2016 06:13	11/12/2016 20:59	10368231006	Lead	20.9	ug/L	HS Mens Bathroom Sink 1
HS E 107 PREP S	10/9/2016 08:05	11/10/2016 19:33	10368231294	Lead	21.9	ug/L	HS E107 Prep Room Sink 1
HS D 125S3	10/9/2016 11:48	11/14/2016 19:12	10368231172	Lead	22.0	ug/L	HS Room D125 Sink 3
HS A 109 PREP S1	10/9/2016 08:09	11/14/2016 18:00	10368231074	Lead	22.3	ug/L	HS A109 Prep Room Sink 1
HS A 106S1	10/9/2016 08:00	11/14/2016 17:47	10368231067	Lead	23.7	ug/L	HS Room A106 Sink 1
HS C 114S2	10/9/2016 10:30	11/14/2016 18:29	10368231130	Lead	23.9	ug/L	HS Room C114 Sink 2
HS F BOY BS4	10/9/2016 06:27	11/17/2016 12:54	10368231314	Lead	24.0	ug/L	HS F Wing Boys Bathroom Sink 4
HS C 114S1	10/9/2016 10:29	11/14/2016 18:28	10368231129	Lead	26.0	ug/L	HS Room C114 Sink 1

HS A 107S3	10/9/2016 08:12	11/14/2016 18:03	10368231077	Lead	30.4	ug/L	HS Room A107 Sink 3
HS A 110 S1	10/9/2016 08:22	11/14/2016 21:20	10368231084	Lead	30.5	ug/L	HS Room A110 Sink 1
HS F BOY BS3	10/9/2016 06:27	11/17/2016 12:53	10368231313	Lead	34.5	ug/L	HS F Wing Boys Bathroom Sink 3
HS C 107S13	10/9/2016 10:25	11/14/2016 18:27	10368231128	Lead	36.0	ug/L	HS Room C107 Sink Facuet 13
HS B 108 S3	10/9/2016 08:43	11/17/2016 12:52	10368231104	Lead	42.9	ug/L	HS Room B108 Sink 3
HS MEN BS2	10/9/2016 06:14	11/12/2016 21:00	10368231007	Lead	44.8	ug/L	HS Mens Bathroom Sink 2
HS B 106S3	10/9/2016 08:36	11/17/2016 12:40	10368231091	Lead	59.1	ug/L	HS Room B106 Sink 3
HS B WOMEN BS3	10/9/2016 09:50	11/17/2016 12:50	10368231099	Lead	62.7	ug/L	HS B Wing Womens Bathroom Sink3
HS A 109S4	10/9/2016 08:07	11/14/2016 17:59	10368231073	Lead	62.9	ug/L	HS Room A109 Sink 4
HS B WOMEN BS1	10/9/2016 09:47	11/17/2016 12:48	10368231097	Lead	64.0	ug/L	HS B Wing Womens Bathroom Sink1
HS B WOMEN BS2	10/9/2016 09:49	11/17/2016 12:49	10368231098	Lead	69.8	ug/L	HS B Wing Womens Bathroom Sink2
HS F 104S	10/9/2016 06:11	11/17/2016 12:55	10368231333	Lead	70.6	ug/L	HS Room F104 Sink
HS G 132S	10/9/2016 07:39	11/12/2016 22:37	10368231054	Lead	87.8	ug/L	HS Room G132 Sink
HS G TEAM OFFICE BS	10/9/2016 06:52	11/12/2016 21:42	10368231026	Lead	95.2	ug/L	HS Girls Team Room Office Bathroom Sink 1
HS B 106 PREP S1	10/9/2016 08:39	11/17/2016 12:47	10368231092	Lead	184	ug/L	HS B106 Prep Room Sink 1

NYSDOH Action Level for Lead