

Sample Identification # and Location	Date/Time Collected	Results	Room Description
MS1041DF2	10/16/2016 08:42	0.12	
MS1047DF2	10/16/2016 08:32	0.13	
MSHALL(2005B)DF2	10/16/2016 07:25	0.13	
MSHALL(1046)DF2	10/16/2016 08:20	0.14	
MSHALL(2005B)DF1	10/16/2016 07:25	0.14	
MSCAFEDF1	10/16/2016 08:42	0.14	
MSCAFEDF2	10/16/2016 08:42	0.14	
MS131S4	10/16/2016 07:34	0.15	
MS1041S3	10/16/2016 08:42	0.15	
MSBOYS(149)BS2	10/16/2016 06:40	0.16	
MSBOY(1001)BS1	10/16/2016 07:01	0.17	
MS1041S1	10/16/2016 08:42	0.17	
MSHALL(125)DF	10/16/2016 07:20	0.18	
MSHALL(1046)DF1	10/16/2016 08:20	0.18	
MS1041S2	10/16/2016 08:42	0.2	
MSBOY(1001)BS3	10/16/2016 07:01	0.21	
MSHALL(212)DF2	10/16/2016 07:43	0.21	
MSHALL(D149)DF	10/16/2016 06:38	0.22	
MSBOY(1001)BS2	10/16/2016 07:01	0.23	
MSGIRLS(016)BS1	10/16/2016 08:30	0.23	
MSGIRL(1005)BS1	10/16/2016 07:06	0.24	
MSBOYS(1046)BS2	10/16/2016 08:24	0.24	
MSGIRLS(1029A)BS3	10/16/2016 06:26	0.26	
MSBOYS(149)BS3	10/16/2016 06:40	0.26	
MSGIRLS(016)BS2	10/16/2016 08:30	0.27	
MSGIRL(1005)BS2	10/16/2016 07:06	0.28	
MSBOYS(1046)BS3	10/16/2016 08:24	0.29	
MSGIRLS(1029A)BS2	10/16/2016 09:15	0.31	
MSHALL(016)DF2	10/16/2016 08:32	0.31	
MSHALL(033)DF	10/16/2016 07:55	0.32	
MSBOYS(149)BS1	10/16/2016 06:40	0.36	
MSGIRL(1005)BS3	10/16/2016 07:06	0.39	
MSGIRL(1046)BS2	10/16/2016 08:24	0.39	
MSGIRLS(0037)BS1	10/16/2016 08:50	0.39	
MSBOYS(016)BS1	10/16/2016 08:25	0.4	
MSCUSTODIALDF	10/16/2016 09:27	0.4	
MSWOMEN(1076)BS3	10/16/2016 07:17	0.41	
MSBOYS(016)BS2	10/16/2016 08:25	0.43	
MSHALL(016)DF1	10/16/2016 08:32	0.43	
MSWOMEN(1076)BS2	10/16/2016 07:17	0.44	
MSGIRL(1046)BS1	10/16/2016 08:24	0.47	
MSHALL(212)DF1	10/16/2016 07:43	0.48	
MSGIRLS(1029A)BS1	10/16/2016 09:15	0.49	
MSPITKITCHENS	10/16/2016 09:05	0.54	
MSWOMEN(0008)BS	10/16/2016 08:35	0.56	
MS134S3	10/16/2016 08:36	0.57	
MSLMCS	10/16/2016 06:20	0.57	
MSGIRLS(122)BS1	10/16/2016 07:02	0.58	
MS1047BS2	10/16/2016 08:32	0.59	
MSPITDF	10/16/2016 09:05	0.6	
MSBOYS(1046)BS1	10/16/2016 08:24	0.61	
MSGIRLS(122)BS2	10/16/2016 07:03	0.61	
MSGIRLS(016)BS3	10/16/2016 08:30	0.62	
MS1044BS	10/16/2016 08:40	0.63	
MSBOYS(139)BS2	10/16/2016 06:37	0.66	
MS130S2	10/16/2016 06:56	0.69	
MSMEN(0008)BS	10/16/2016 08:35	0.69	
MS150S5	10/16/2016 06:33	0.75	

MS016S3	10/16/2016 08:18	0.75	
MS131S3	10/16/2016 07:34	0.76	
MSCUSTODIALBS	10/16/2016 09:27	0.76	
MSFACULTY(212)BS	10/16/2016 07:40	0.77	
MSHALL(1001)DF2	10/16/2016 06:59	0.78	
MS1047BS1	10/16/2016 08:32	0.78	
MSGIRLS(037)BS1	10/16/2016 07:53	0.78	
MSWOMEN(1076)BS1	10/16/2016 07:17	0.79	
MSGIRLS(0037)BS2	10/16/2016 08:50	0.81	
MS133S3	10/16/2016 07:34	0.83	
MS1047BS3	10/16/2016 08:32	0.83	
MS041S1	10/16/2016 08:02	0.84	
MSMEN(1076)BS3	10/16/2016 07:09	0.88	
MSGIRLS(037)BS2	10/16/2016 07:53	0.88	
MSBOYS(139)BS1	10/16/2016 06:36	0.89	
MSBOYS(016)BS3	10/16/2016 08:25	0.93	
MSBOYS(0037)BS	10/16/2016 08:50	0.94	
MS135S2	10/16/2016 07:38	0.95	
MS116S2	10/16/2016 06:55	0.98	
MS150S2	10/16/2016 06:33	1.0	
MS143S1	10/16/2016 08:00	1.0	
MS132S2	10/16/2016 06:46	1.0	
MSGIRLS(2002)BS1	10/16/2016 07:36	1.0	
MSHALLDF0037	10/16/2016 08:50	1.0	
MS125S3	10/16/2016 07:16	1.1	
MS1076S	10/16/2016 07:14	1.1	
MS016S2	10/16/2016 08:18	1.1	
MS1051BS	10/16/2016 08:38	1.2	
MS1036S2	10/16/2016 08:56	1.2	
MS117S	10/16/2016 06:56	1.3	
MS125S4	10/16/2016 07:16	1.3	
MS135S1	10/16/2016 07:38	1.3	
MS135S3	10/16/2016 07:38	1.3	
MSGIRLS(2002)BS2	10/16/2016 07:36	1.3	
MS015S	10/16/2016 08:23	1.3	
MSHALL(0066)DF	10/16/2016 09:18	1.3	
MS150S3	10/16/2016 06:33	1.4	
MSMEN(1076)BS1	10/16/2016 07:09	1.4	
MSGIRLS(2002)BS3	10/16/2016 07:37	1.4	
MS150S4	10/16/2016 06:33	1.5	
MSHALL(1001)DF1	10/16/2016 06:59	1.5	
MS1036S1	10/16/2016 08:56	1.5	
MSPITGIRLLSBS2	10/16/2016 09:00	1.5	
MSBOYS(212)BS2	10/16/2016 07:45	1.5	
MS039S1	10/16/2016 09:10	1.5	
MS131S1	10/16/2016 07:34	1.6	
MS131S2	10/16/2016 07:34	1.6	
MS145S2	10/16/2016 08:08	1.6	
MS1082BS	10/16/2016 07:06	1.6	
MSBOYS(212)BS1	10/16/2016 07:45	1.6	
MS150S1	10/16/2016 06:33	1.7	
MS1033BS	10/16/2016 08:55	1.7	
MS030S	10/16/2016 07:57	1.7	
MS130S1	10/16/2016 06:55	1.8	
MS116S1	10/16/2016 06:55	1.9	
MS133S4	10/16/2016 07:34	1.9	
MS134S1	10/16/2016 06:40	1.9	
MS043S	10/16/2016 09:05	1.9	
MS035S	10/16/2016 09:13	1.9	
MS143S3	10/16/2016 08:00	2.0	
MS145S5	10/16/2016 08:08	2.0	
MS132S1	10/16/2016 06:45	2.0	
MSSTAFF(122)BS	10/16/2016 07:00	2.0	

MS141S4	10/16/2016 07:46	2.1	
MS045S	10/16/2016 09:05	2.1	
MS116S3	10/16/2016 06:55	2.2	
MS143PREPS	10/16/2016 08:00	2.2	
MSPITBOYSBS2	10/16/2016 09:02	2.2	
MSBOYS(212)BS3	10/16/2016 07:45	2.2	
MS041S3	10/16/2016 08:02	2.2	
MS145S4	10/16/2016 08:08	2.3	
MS142S5	10/16/2016 06:32	2.3	
MS016S1	10/16/2016 08:18	2.3	
MS143S2	10/16/2016 08:00	2.4	
MSMEN(1076)BS2	10/16/2016 07:09	2.4	
KITCHEN 0023	10/16/2016 09:25	2.4	
MS135S4	10/16/2016 07:38	2.5	
MS141S3	10/16/2016 07:46	2.5	
MS145S3	10/16/2016 08:08	2.6	
MS021S3	10/16/2016 09:00	2.6	
MS041S2	10/16/2016 08:02	2.6	
MS125S1	10/16/2016 07:16	2.7	
MS143S4	10/16/2016 08:00	2.7	
MSSTAFFRESTROOMBS	10/16/2016 06:25	2.8	
MS145S1	10/16/2016 08:08	2.9	
MS133S2	10/16/2016 07:34	3.1	
MSPITGIRLLSBS1	10/16/2016 09:00	3.1	
MS1082S	10/16/2016 07:07	3.1	
MSBOYSTEAMBS2	10/16/2016 09:20	3.1	
1037 DF	10/16/2016 08:55	3.1	
MS141S5	10/16/2016 07:46	3.3	
MS141PREPS	10/16/2016 07:48	3.4	
MS141S2	10/16/2016 07:46	3.6	
MS142S6	10/16/2016 06:33	3.6	
MS142S4	10/16/2016 06:31	3.7	
MS021S1	10/16/2016 08:55	4.0	
MS142S1	10/16/2016 06:28	4.2	
MS131PREPS	10/16/2016 07:34	4.3	
MS021S4	10/16/2016 09:00	4.3	
MS021S2	10/16/2016 09:00	4.6	
MSPITBOYSBS1	10/16/2016 09:02	4.7	
MS021S5	10/16/2016 09:00	4.7	
MS204S1	10/16/2016 07:31	4.9	
MS141S6	10/16/2016 07:46	5.0	
MSSTUDENTRESTROOMBS	10/16/2016 06:26	5.3	
MS134S2	10/16/2016 06:41	5.4	
MS142S2	10/16/2016 06:29	5.5	
MS039S2	10/16/2016 09:10	5.5	
MS143S5	10/16/2016 08:00	6.0	
MS125S2	10/16/2016 07:16	6.2	
MS141S1	10/16/2016 07:46	6.8	
MSBOYSTEAMBS1	10/16/2016 09:20	7.0	
MS133S1	10/16/2016 07:34	9.1	
MS142S3	10/16/2016 06:30	13.8	
MSRESTROOM(0077)BS1	10/16/2016 09:22	15.1	MS Restroom 0077 Bathroom Sink 1
MS145S6	10/16/2016 08:08	15.3	MS Room 145 Sink Facuet 6
MSPAPERSTORAGES	10/16/2016 09:16	16.6	MS Paper Storage Sink
MS143S6	10/16/2016 08:00	19.2	MS Room143 Sink Facuet 6
MSRESTROOM(0077)BS2	10/16/2016 09:23	30.4	MS Restroom 0077 Bathroom Sink 2
MS0041S2	10/16/2016 08:15	156	MS Science Room 0041 Sink Facuet 2
MS1047DF1	10/16/2016 08:32	<0.10	
MS1041DF1	10/16/2016 08:42	<0.10	
MSICEMACHINE(0007)	10/16/2016 08:40	<0.10	

NYSDOH Action Level for Lead of 15 ppb